

GOALS, OBJECTIVES AND POLICIES

Goal 1.0.0. Maintain a wastewater collection and transmission system to ensure its adequacy to protect the health and safety of all residents and businesses in the City.

Objective 1.1.0. Continue to provide wastewater collection and transmission that will satisfy existing and projected growth.

Measure - Extent of compliance with the ratio of wastewater transmission metered to "large user agreement" reservation and extent to which levels of service are maintained.

Policy 1.1.1. The City shall continue to rely upon the facilities and personnel of the Coral Springs Utilities Division, the North Springs Improvement District (NSID), the Coral Springs Improvement District (CSID) and Royal Utilities (or its successors) to satisfy the wastewater collection and transmission needs of residents and businesses within their respective service areas.

Policy 1.1.2. The City's Utilities Division, being a large user of the Broward County North Regional Wastewater Transmission and Treatment Facilities, shall cooperate with Broward County, via the Large Users Advisory Board, in periodically undertaking studies to evaluate its wastewater collection and transmission system to ensure its continued adequacy.

The City shall encourage the NSID, the CSID and Royal Utilities (or its successors) to undertake similar studies to assure adequacy of facilities to meet the City of Coral Springs needs within their respective service areas.

The master plans resulting from these studies will recommend definite steps to:

1. Identify and reduce sources of infiltration and inflow (I/I) into the wastewater collection system as a means of reducing wastewater flows.
2. Provide facilities that will ensure adequate and safe wastewater disposal.

Policy 1.1.3. The City's Utilities Division shall continue to transfer wastewater to master pump stations, owned and operated by Broward County, for treatment at the North Broward Regional Plant.

The City shall encourage the NSID, the CSID, and Royal Utilities (or its successor) to do the same.

SANITARY SEWER SUB-ELEMENT

Policy 1.1.4. The City's Utilities Division shall continue with its efforts to identify and reduce sources of infiltration and inflow (I/I) into the gravity sewer system.

Policy 1.1.5. The following level of service standards are hereby adopted:

<u>Water Service Area</u>	<u>Level of Service Standard/ gallons per capita per day</u>
Coral Springs Public Utilities	122.00
North Springs Improvement District	117.24
Royal Utilities	134.00
Coral Springs Improvement District	113.51

Policy 1.1.6. To calculate sanitary sewer demand, the City shall utilize the following as the basis for determining the availability of facility capacity and the demand generated by a development:

Facility/Service Area	Level of Service Standard
Sanitary Sewer City-Wide	Sewage Availability
Single-Family Residential	375 gpd/du
Multi-Family Residential	333 gpd/du
Commercial/Industrial	2,000 gpd/acre
Public/Civic	2,000 gpd/acre